



# Certificate of Compliance

**Certificate:** 1973728 (LR 66765)

**Master Contract:** 162136

**Project:** 2219967

**Date Issued:** 2010/01/22

**Issued to:** Eaton Yale Company  
5050 Mainway  
Burlington, ON L7L 5Z1  
Canada  
Attention: Mr. Tony Kranendonk

*The products listed below are eligible to bear the CSA Mark shown*



*T. Munteanu, P.Eng.*

**Issued by:** T. Munteanu, P.Eng.

## **PRODUCTS**

**CLASS 3211 04** - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Magnetic

Across-the-line combination magnetic motor controllers with fusible and non-fusible disconnect switches, enclosed Cat. Nos. ECX, followed by 19 or 20, followed by B, C, D, E, F, G, H, J, K, L, M, N and P with suffixes rated 115A max, 100 hp max, 600 V ac, 3 phase; coil voltage 24V dc, 600V ac max; ratings as per report. These devices are provided with CSA Type 1, 3R, 4, 4X or 12 enclosures.

Across-the-line combination magnetic motor controllers with HMCP circuit breakers, enclosed Cat Nos ECX followed by 25 or 26, followed by B, C, D, E, F, G, H, J, K, L, M, N, P, Q, R, S, T and U with suffixes, rated 300A max, 300 hp max, 600V ac, 3 phase; coil voltage 24V dc, 600V ac max; ratings as per report. These devices are provided with Type 1, 3R, 4, 4X or 12 enclosures.

## **APPLICABLE REQUIREMENTS**

CSA C22.2 No. 14 - Industrial Control Equipment

CAN/CSA C22.2 No. 94 - Special Purpose Enclosures