



Cutler-Hammer

Switch Position Indicator for Pringle Type QA, CBC & FP Switches

Instruction Sheet J

December 2008

Switch in the CLOSED position

When the switch is in the fully closed position the word CLOSED will be in the center of the opening in the trim plate and parallel to the floor.

Switch in the OPEN position

When the switch is in the fully open position the word OPEN will be in the center of the opening in the trim plate and parallel to the floor.

WARNING

Do not attempt to install switches or perform maintenance on equipment while it is energized. Failure to following this warning could lead to death or severe injury. Always verify that no voltage is present on all switch terminals prior to servicing. While energized, an arc flash and shock hazard exists. Consult NFPA 70E and OSHA guidelines for operator safety prior to servicing equipment.

CAUTION

If the above cannot be verified then care should be taken. A visual inspection of the switch contacts may be necessary. Turn off power ahead of switch before removing covers for inspection.

Eaton Corporation
1000 Cherrington Pkwy
Moon Township, PA 15108-4312
United States
Tel: 877-ETN-CARE
www.Eaton.com

© 2008 Eaton Corporation
All Rights Reserved
Printed in USA
Publication No. IL00808001E
December 2008



Cutler-Hammer